

**SMITH DESIGN GROUP, INC.**

307 Church Street Suite B  
LaGrange, Georgia 30240  
Phone (706) 882-5511 Fax (706) 883-7777

**Addition to the  
Senior Center**

Architect's Project No. 0603  
August 7, 2008

**ADDENDUM NUMBER THREE**

**The Bidding Documents are modified as follows:**

**PART 1.00 DRAWINGS**

- 1.01 Sheet S-4**
  - A. Keynote 3; Last sentence change to read “At All Exterior Walls”.**
  
- 1.02 Sheet A-1**
  - A. See Sheet A1-2 for correct floor plan of new addition**
  
- 1.03 Sheet A2-3**
  - A. CHM-4 to be aluminum store front; VW-1, VW-2, VW-3 to be hollow metal frames with depths to work with wall thickness.**
  
- 1.04 Sheet A2-5:**
  - A. Detail 1/A2-5 change “2x8’s@ 16” O.C.” to read “2x8’s @12” O.C.” Also change “1/2 inch foil faced insulating sheathing to read, “1/2 inch CDX plywood sheathing with self-adhering 20 Mil vapor barrier, floor to eave.”**
  - B. Details 2/A2-5, 3/A2-5, 4/A2-5, 5/A2-5 see sheet S-4 for locations where stubs are to be spaced at 12” O.C. for load bearing.**
  
- 1.05 Sheet A5-1**
  - A. Detail 1/A5-1; change “5/8 inch CDX Plywood to read “1/2 inch CDX plywood”.**
  
- 1.06 Sheet AE-1**
  - A. See Sheet A1-2 for correct floor plan of new addition.**

**PART 2.00 - PROJECT MANUAL**

**No Items Included**

**PART 3.00 ADDENDA**

**3.01 Addendum No. 1**

- A. Please refer to Addendum No. 1 for correct location that bids will be received.

**PART 4.00 – APPROVED MANUFACTURERS**

**No Items Included**

**PART 5.00 – ATTACHMENT**

**No Items Included**

**PART 6.00 – GENERAL CLARIFICATIONS**

**No Items Included**

**END OF ADDENDUM NUMBER THREE**

**AD3-2\***