

SMITH DESIGN GROUP, INC.

307 Church Street Suite B
LaGrange, Georgia 30240
Phone (706) 882-5511 Fax (706) 883-7777

**Long Cane Fire Station
Electrical – Bid Package No. 5
June 22, 2011**

Architect's Project No. 1009
June 22, 2011

ADDENDUM NUMBER ONE

The Bidding Documents are modified as follows:

PART 1.00 DRAWINGS
NO ITEMS INCLUDED

PART 2.00 PROJECT MANUAL
NO ITEMS INCLUDED

PART 3.00 ADDENDA
NO ITEMS INCLUDED

PART 4.00 – APPROVED MANUFACTURERS
NO ITEMS INCLUDED

PART 5.00 – ATTACHMENT
5.01 Replace lighting fixture schedule with new schedule on
attached drawings ADD1-1A

PART 6.00 – GENERAL CLARIFICATIONS
NO ITEMS INCLUDED

END OF ADDENDUM NUMBER ONE

AD1-1*

Lighting Fixture Schedule

TYPE	MANUFACTURER	CATALOG NUMBER	LAMP QUANTITY AND TYPE	VOLTAGE	MOUNTING METHOD	DESCRIPTION / REMARKS	PRICE
A	LITHONIA	RT5X 2 28T5 MVOLT GEB95S LPM835P	2 28W T5	UNV	SURFACE	1X4 SURFACE VOLUMETRIC FIXTURE WITH STEP DIMMING	260
AX	LITHONIA	RT5X 2 28T5 MVOLT GEB95S LPM835P EL14	2 28W T5	UNV	SURFACE	1X4 SURFACE VOLUMETRIC FIXTURE WITH STEP DIMMING W/EMERGENCY	395
B	LITHONIA	REAL6 D6A L7XLED	LED	120	RECESSED	6" RECESSED IC RATED DOWNLIGHT AND TRIM	68
C	LITHONIA	REAL6 D6A L7XLED	LED	120	RECESSED	6" RECESSED IC RATED DOWNLIGHT AND TRIM	68
D	LITHONIA	REAL6 D6A L7XLED	LED	120	RECESSED	6" RECESSED IC RATED DOWNLIGHT AND TRIM WET LISTED FOR SHOWER	68
E	LITHONIA	10842RE T5 BNP	14W T5	120	SURFACE	24" FLUORESCENT VANITY LIGHT	74
F	LITHONIA	WB 2 17 A12 MVOLT GEB10IS LP835 WH	2 17W T8	UNV	WALL	24" WALL BRACKET OVER DOOR	215
G	LITHONIA	2UC 17 120 GEB10IS LP835P SWR	1 17W T8	120	SURFACE	24" UNDER CABINET LIGHT	64
I	LITHONIA	C 2 32 MVOLT GEB10IS WGCUNST	2 32W T8	UNV	SURFACE	48" STRIP LIGHT WITH WIREGUARD	45
J	LITHONIA	TMS8 3 32 ND 120 GEB10RS MSI LP835	6 32W T8	120	SURFACE	96" FLUORESCENT HIGH BAY IB/OB SWITCHING WITH INTEGRAL OCC SENSOR	330
WAX	LITHONIA	LF6N 2/26DTT F602AZ MVOLT EL WLP35	2 26W CFL	UNV	RECESSED	6" RECESSED 2/26W DTT HORIZONTAL LAMPS	260
WB	LITHONIA	WSR 42TRT 277 ELDW PE FINISH LPI (MUST SPECIFY VOLTAGE WITH EMERGENCY OPTION)	1 42TRT CFL	277	WALL	DECORATIVE WALL PACK WITH INTEGRAL EMERGENCY	510

NOTES

1. Any alternates must be submitted 14 days prior to bid date to be considered. Alternate fixtures must be submitted with a full color spec sheet, photometric report, finish chip set and working sample. Submission of alternate fixture does not guarantee approval and will only be accepted if listed on an addendum to the fixture schedule. Bid should be submitted as specified only.

ADD1-1A _ BID PACKAGE NO.5 ELECTRICAL